

SMITH PREDICTOR AND ITS MODIFICATIONS

Hang C. C.

Department of Electrical Engineering, National University of Singapore, Singapore.

Keywords: Dead time, PID control, Smith predictor, process model, transfer function, Ziegler-Nichols tuning, phase margin, load disturbance, steady-state error, non-minimum phase system, high order system, open-loop unstable system, load estimator.

Contents

1. Introduction
2. Controller design
3. Performance comparison
4. Modification for high order systems
5. Modification for rapid load rejection
6. Modifications for open-loop unstable systems

Glossary

Bibliography

Biographical Sketch

Summary

The Smith predictor is a model-based controller that is effective for processes with long dead time. It has an inner loop with a main controller that can be simply designed without the dead time. The effects of load disturbance and modeling error are corrected through an outer loop. The Smith predictor can also be used for processes with significant non-minimum phase dynamics and for high order systems that exhibit apparent dead time.

A modification using a rapid load detector scheme can be applied to further improve the load response. Three modifications of the Smith predictor for open-loop unstable systems are outlined. They are based on a mismatched process model, a static load estimator, and a rapid load detector, respectively, and the main purpose of the modifications is to ensure stability and zero steady-state error to step load disturbances. Simulation results are given to demonstrate the achievable performance.

1. Introduction

In the process industries, the occurrence of “dead time” or “transportation lag” is quite common. For the majority of simple control loops, the amount of dead time is usually not significant when compared to the time constant. For more complicated control loops like those for quality control, dead time can be very significant and may even be longer than the system time constant.

The reasons for this may include analysis delay and the down-stream location of the sampling point for the quality analyzer. Another class of examples is characterized by a multitude of small lags, such as a long bank of heat exchangers, or a distillation column

with many trays, giving rise to what is called “apparent” dead time.

It has been found in practice that the widely used PID controller would rapidly lose its effectiveness when the process dead time becomes significant. The consequence is that many important control loops such as those for quality control, are either poorly regulated or are left on manual status, which then necessitates the frequent and close attention of the plant operators. From a theoretical viewpoint, it has been established in many standard control textbooks that without any dead time compensation, the gain cross over frequency, ω_c , has an upper bound, namely

$$\omega_c < 1/L$$

where L is the amount of dead time. The achievable speed of response is hence inversely proportional to the dead time.

If the major disturbance to the process could be measured, the most effective way to cope with the problem of long dead time is by means of “feedforward” control. If it cannot be accurately measured and used in feedforward control, dead time compensation will have to be introduced if tight control is desired. The simplest dead time compensation method for a stable, well-damped process is the Smith predictor. For a process with poor damping, the more sophisticated pole-placement or other more advanced control will be more appropriate.




Figure 1. Structure of the Smith predictor.

The principle of the Smith predictor can be easily illustrated through the control of a process with the following transfer function:

$$G_1(s) = \frac{k_p e^{-sL}}{1 + s\tau} \tag{1}$$

where k_p , L and τ are the process static gain, dead time, and time constant, respectively. As shown in Figure 1, the Smith predictor is a model-based controller that has two loops. In the inner loop, it uses the process model without the dead time to predict the output y_a which is fed back to the main controller $C_1(s)$ to generate the appropriate control signal, u , so that the process output will track the setpoint or reference signal, r .

As this loop does not contain the dead time, the controller gain can be selected to be high to achieve fast and well-damped setpoint responses. The effects of any unmeasurable load disturbance, d , and small modeling errors are then corrected by feeding back the predictor error, e_p , through the outer loop as shown in Figure 1.

2. Controller design

The design of the main controller $C_1(s)$ in the Smith predictor as shown in Figure 1 assumes that the process model parameters k_p , L and τ , are known. For the first order process model, $C_1(s)$ can be simply chosen to be a proportional-Integral (PI) controller of the form:

$$C_1(s) = k_{c1} \left(1 + \frac{1}{sT_{i1}} \right) \quad (2)$$

Assuming that the desired response without the dead time part should have a time constant T_m , we have

$$\frac{y(s)}{e^{-sL}r(s)} = \frac{1}{1 + sT_m} = \frac{C_1(s)k_p/(1+s\tau)}{1 + C_1(s)k_p/(1+s\tau)} \quad (3)$$

Solving equations (2) and (3), the following controller design is obtained:

$$T_{i1} = \tau \quad (4)$$

$$k_{c1} = \frac{\tau}{k_p T_m} \quad (5)$$

The desired T_m is usually specified as a ratio of T_m to the process time constant τ . A suitable range of this ratio taking into account of possible controller saturation and noise sensitivity is 0.2 to 1.

While many real-life processes could be adequately modeled by the first-order plus dead time model of equation (1), it is widely known that some high-order processes could be better approximated by the following second-order plus dead time model:

$$G_2(s) = \frac{k_p e^{-sL}}{(1 + s\tau_2)^2} \tag{6}$$

The Smith predictor structure will be the same as Figure 1 except that the first order model will be replaced by the second order model. Assuming the desired response, without the dead time part, should have a natural frequency w_o and a damping factor ξ , we have

$$\frac{w_o^2}{s^2 + 2\xi w_o s + w_o^2} = \frac{C_1(s)k_p / (1 + s\tau_2)^2}{1 + C_1(s)k_p / (1 + s\tau_2)^2} \tag{7}$$

If $C_1(s)$ is chosen to be a PI controller, a simple solution is

$$T_{i1} = \tau_2 \tag{8}$$

$$k_{c1} = 1 / (4\xi^2 k_p) \tag{9}$$

Another practical consideration is the robustness of the controller when there is modeling error, especially a mismatch in the dead time. The controller gain in (5) and (9) may have to be reduced to accommodate a significant mismatch. This can be guided by a simple analytical study. For instance, if $G_1(s) = G(s) e^{-sL}$ and there is a modeling error of ΔL in the dead time, the Smith predictor can be represented by the equivalent structure of Figure 2.




Figure 2. Structure of the Smith predictor with mismatch in dead time

It is straightforward to obtain:

$$H(s) = 1 + e^{-s(L + \Delta L)} - e^{-sL} \tag{10}$$

The controller gain should then be suitably adjusted to ensure that the closed-loop

transfer function without mismatch has sufficient attenuation, say greater than 6 dB, at the frequencies where $H(j\omega)$ has resonance peaks.

-
-
-

TO ACCESS ALL THE 18 PAGES OF THIS CHAPTER,
[Click here](#)

Bibliography

Astrom K. J., Hang C. C., and Lim B. C. (1994) A new Smith predictor for controlling a process with an integrator and long dead-time. *IEEE Trans. on Automatic Control*. **39** (2), 343-345. [This work allows load disturbance response to be designed independent of the setpoint response].

Hang C. C., Wang Q. G., and Cao L. S. (1995) Self-tuning Smith predictors for processes with long dead time. *Int. Journal of Adaptive Control and Signal Processing*. **9** (9), 255-270. [This work reports on the auto-tuning of Smith predictor and includes the use of low-order models].

Hang C. C., and Wong F. S. (1979) Modified Smith predictors for the control of processes with dead time. *Proc. Instrument Society of America Annual Conference*, 33-34. [This work introduces the rapid load detector for improved load disturbance response of a Smith predictor].

Matausek M. R. and Micic A. D. (1996) A modified Smith predictor for controlling a process with an integrator and long dead-time *IEEE Trans. on Automatic Control*. **41** (8), 1199-1203. [This work uses a load estimator to modify the Smith predictor for a process containing an integrator].

Matausek M. R., and Micic A. D. (1999) On the modified Smith predictor for controlling a process with an integrator and long dead-time. *IEEE Trans. on Automatic Control*. **44** (8), 1603-1606. [This work introduces a derivative term to improve the speed of response of the modified Smith predictor].

Normey-Rico J.E., and Camacho E.F. (1999) Robust tuning of dead-time compensators for processes with an integrator and long dead-time. *IEEE Trans. on Automatic Control*. **44** (8), 1597-1603. [This work uses a mismatched model to eliminate the steady-state error for the Smith predictor control of a process containing an integrator].

Santacesaria C. and Scattolini R. (1993) Easy tuning of Smith predictor in the presence of delay uncertainty. *Automatica* **20** (6), 1595-1597. [This work addresses controller design for robustness].

Smith O. J. (1959) A controller to overcome dead-time. *ISA Journal* **6** (2), 28-33. [This is the first classical paper to present the Smith predictor for overcoming the effect of long dead-time].

Watanabe K. and Ito M. (1981) A process-model control for linear systems with delay. *IEEE Trans. on Automatic Control* **26** (6), 1261-1266. [This is the first paper to propose a modified Smith predictor using a mismatched process model to eliminate steady-state error for a process containing an integrator].

Biographical Sketch

Professor HANG CHANG CHIEH (C.C. Hang) graduated with a First Class Honours Degree in Electrical Engineering from the University of Singapore in 1970. He received the Ph.D. degree in Control Engineering from the University of Warwick, England, in 1973. From 1974 to 1977, he worked as a Computer and Systems Technologist in the Shell Eastern Petroleum Company (Singapore) and the Shell International Petroleum Company (The Netherlands). Since 1977, he has been with the National University of Singapore, serving in various positions including being the Vice-Dean of the Faculty of Engineering and Head of the Department of Electrical Engineering. From 1994 to 2000, he served as the Deputy Vice-Chancellor in charge of research. His major area of research is adaptive control, in which he

has published two books, 230 international journal and conference papers and 6 patents. He was a Visiting Scientist in Yale University in 1983, and in Lund Institute of Technology in 1987 and 1992. From 1992 to 1999, he served as Principal Editor (Adaptive Control) of the *Automatica* Journal. He was elected a Fellow of IEEE in 1998, a Fellow of Third World Academy of Sciences in 1999 and a Foreign Member of the Royal Academy of Engineering, UK, in 2000. He received his D.Sc. degree from the University of Warwick in 2001.

UNESCO – EOLSS
SAMPLE CHAPTERS